

Columbia County Department of Health

71 North 3rd Street Hudson, ◆ NY 12534 ◆ (518) 828-3358 ◆ Fax (518) 828-2666

Nancy A. Winch, R.N., M.S. Public Health Director

Richard	Coo	n
1840 Ro	ute 9	H
Hudson,	NY	12534

Dear Applicant:								
These requirements for the sewage disposal system to serve your proposed 3 bedroom dwelling located at 2142 County Route 21, Tax Map#64-00-01-41, Kinderhook Town, consists of the following:								
SEPTIC X	1000 gallon	Tile field:	5 @_50	_ '-	250	TOTAL '		
	1250 gallon	Seepage Pit _		_ 'diameter x		'DEPTH		
These requirements are based on standards for typical in-ground sewage systems which are acceptable to the Columbia County Department of Health. Additional requirements relating to minimum separation distances are also necessary and may be referenced in the following table:								
	PROPERTY LINE	WELL	SURFACE	WATER	DWEL	LING		
Septic Tank	10	50	5	50		10		
Tile Field	10	100	10	100		20		
Seepage Pit	10	150	10	100		20		
SPECIAL CONSIDERATIONS: Locate well minimum of 150' from leach field due to presence of excessively drained soil. Field mark approved leach field area. *******THESE REQUIREMENTS APPLY TO THE AREA OF THE TEST SITE ONLY*******								
Prior to backfill, our Department <u>must</u> be contacted to allow for an inspection. Questions during construction should be referred to our personnel at (518) 828-3358.								
Very truly yours, Dala F. Reference Soutomber 1, 2010								
Dale E. Rowe September 1, 2010								